



# Power

## Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH15
PS401 HOME BASE UNIT				
PS401.01	Home Base with Practical Activities Area	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS401.11	Home Base Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS401.21	Withdrawal Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS401.22	Shared Withdrawal Room	GENERAL POWER OUTLETS 2 double socket outlets	-	-
PS401.31	Practical Activities Area	GENERAL POWER OUTLETS 1 double socket outlet	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS401.32	Shared Practical Activities Area	GENERAL POWER OUTLETS Type 2 - 2 double socket outlets Type 3 - 3 double socket outlet Type 4 - 3 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS401.41	Personal Effects Storage	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS430 SPECIAL EDUCATION LEARNING UNIT - IO/IS/P				
PS430.01	Home Base with Practical Activities Area - IO	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS430.02	Home Base with Practical Activities Area - IS/P	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS430.11	Home Base Store Room - IO/IS/P	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS430.21	Withdrawal Area - IO/IS/P	GENERAL POWER OUTLETS 1 double socket outlets	-	-
PS430.22	Shared Withdrawal Room - IO/IS/P	GENERAL POWER OUTLETS 2 double socket outlets	-	-
PS430.31	Practical Activities Area - IO/IS/P	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS430.32	Shared Practical Activities Area - IO/IS/P	GENERAL POWER OUTLETS Type 2 - 3 double socket outlets & 3 single socket outlets Type 3 - 4 double socket outlet & 3 single socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS430.41	Personal Effects Storage - IO/IS/P	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS440 SPECIAL EDUCATION LEARNING UNIT - BD/CD/ED				
PS440.01	Home Base with Practical Activities Area - BD/CD/ED	GENERAL POWER OUTLETS 4 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-



# Power

## Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH15
PS440.31	Practical Activities Area - BD/CD/ED	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS501 LIBRARY UNIT				
PS501.01	Library Main Area - Small	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS501.03	Library Main Area - Large	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS501.11	Office / Workroom	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS501.12	Shared Office / Workroom	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS501.21	Communications Room	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS501.31	KLA Resource Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS502 SPECIAL PROGRAMS UNIT				
PS502.01	Special Programs Room	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS502.03	Special Programs Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS503 COMMUNAL HALL UNIT				
PS503.01	Communal Hall - Small	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS503.02	Communal Hall - Large	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS503.11	Chair Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS503.21	PE Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS503.31	Sports Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS503.41	Performance Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-



# Power

## Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH15
PS503.51	Sound Cupboard	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	-	-
PS504 COVERED OUTDOOR LEARNING AREA (COLA)				
PS504.01	Covered Outdoor Learning Area (COLA)	-	-	-
PS504.03	Covered Outdoor Space	-	-	-
PS505 GAMES UNIT				
PS505.01	Games Court	-	-	-
PS506 KILN UNIT				
PS506.01	Kiln Room	-	-	-
PS601.01	Entry Vestibule	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS601.11	Principal's Office	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS601.12	Principal / Meeting Room	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS601.13	Deputy Principal's Office	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS601.14	Deputy Principal - Double Office	GENERAL POWER OUTLETS 4 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS601.15	Interview Room / Office	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS601.16	Interview Room	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS601.21	Clerical / Printing	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS601.23	Clerical/Printing/Workroom	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS601.41	Security Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-



# Power

## Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH15
PS601.51	Sick Bay	GENERAL POWER OUTLETS Type 1 - 1 double socket outlet Type 2 - 2 double socket outlets Type 3 - 3 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS601.71	Community Clinic	GENERAL POWER OUTLETS 3 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS601.81	Entrance Zone	-	-	-
PS602 STAFF UNIT				
PS602.01	Staff Room	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS602.03	Staff Room - Adjoining Annex	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS602.11	Staff Toilet	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	-	-
PS602.12	Access Shower/Toilet	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	-	-
PS602.21	Staff Room Annex	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS603 STUDENT AMENITIES				
PS603.01	Toilets	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	-	-
PS603.03	Drinking Facilities	-	-	-
PS603.04	Hand Washing Outlets	-	-	-
PS603.05	Seating	-	-	-
PS603.06	Access Shower/Toilet/Change	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	-	-
PS603.09	Laundry	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS604 CANTEEN UNIT				
PS604.01	Canteen	GENERAL POWER OUTLETS General power outlets required. Refer to Design Guide	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS604.11	Canteen Office / Store Room			



# Power

## Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH15
PS604.21	Canteen Servery Covered Area	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	POWER - OTHER Other power considerations may apply. Refer to Design Guide
PS605 STORAGE UNIT				
PS605.01	Garden Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS605.11	Bulk Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS605.21	Cleaning Supplies Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS605.31	Cleaning Distributed Store Room	-	-	-
PS607 ASSEMBLY COURT				
PS607.01	Assembly Area	-	-	-
PS607.11	Flagpole	-	-	-
PS607.21	Assembly Zone	-	-	-
PS608 PEDESTRIAN CIRCULATION				
PS608.01	Paved Areas	-	-	-
PS608.02	Paved Access	-	-	-
PS609 VEHICULAR CIRCULATION				
PS609.01	Service Roads	-	-	-
PS609.11	Bulk Waste Pad	-	-	-
PS609.21	Car Parking	-	-	-
PS609.31	Bus Zone	-	-	-
PS609.41	Bicycle Storage Area	-	-	-
PS609.51	Crossovers	-	-	-
PS610 OPEN SPACES				
PS610.01	Free Play Area	-	-	-
PS610.02	Passive Play/Open Areas	-	-	-
PS610.11	Street Frontage Zone	-	-	-
PS610.12	Active Zone	-	-	-
PS610.13	Passive Zone	-	-	-
PS610.14	Boundary Zone	-	-	-
PS610.15	Out of Bounds Zone	-	-	-
PS610.16	Special Function Zone	-	-	-
PS611 SERVICES				
PS611.01	Main Switchboard Cupboard	-	-	-
PS611.02	Distribution Board Cupboard	-	-	-
PS611.11	Services Zone	-	-	-
PS612 SITE				
PS612.01	Fencing	-	-	-
PS612.11	Waste Recycling	-	-	-
PS612.21	Signs	-	-	-
PS612.31	Site	-	-	-



# Power

## Schedule for Primary School Rooms & Spaces

ID	ROOM/SPACE NAME	GPO	CM	OTH15
PS401 HOME BASE UNIT				
PS401.01	Home Base with Practical Activities Area	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS401.11	Home Base Store Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS401.21	Withdrawal Room	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS401.22	Shared Withdrawal Room	GENERAL POWER OUTLETS 2 double socket outlets	-	-
PS401.31	Practical Activities Area	GENERAL POWER OUTLETS 1 double socket outlet	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS401.32	Shared Practical Activities Area	GENERAL POWER OUTLETS Type 2 - 2 double socket outlets Type 3 - 3 double socket outlet Type 4 - 3 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS401.41	Personal Effects Storage	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS430 SPECIAL EDUCATION LEARNING UNIT - IO/IS/P				
PS430.01	Home Base with Practical Activities Area - IO	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS430.02	Home Base with Practical Activities Area - IS/P	GENERAL POWER OUTLETS 5 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS430.11	Home Base Store Room - IO/IS/P	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS430.21	Withdrawal Area - IO/IS/P	GENERAL POWER OUTLETS 1 double socket outlets	-	-
PS430.22	Shared Withdrawal Room - IO/IS/P	GENERAL POWER OUTLETS 2 double socket outlets	-	-
PS430.31	Practical Activities Area - IO/IS/P	GENERAL POWER OUTLETS 2 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS430.32	Shared Practical Activities Area - IO/IS/P	GENERAL POWER OUTLETS Type 2 - 3 double socket outlets & 3 single socket outlets Type 3 - 4 double socket outlet & 3 single socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-
PS430.41	Personal Effects Storage - IO/IS/P	GENERAL POWER OUTLETS 1 double socket outlet	-	-
PS440 SPECIAL EDUCATION LEARNING UNIT - BD/CD/ED				
PS440.01	Home Base with Practical Activities Area - BD/CD/ED	GENERAL POWER OUTLETS 4 double socket outlets	CABLE MANAGEMENT Cable management to be considered. Refer to Design Guide	-