



SCHOOL TYPE
KEY LEARNING / SUPPORT AREA
ROOM / SPACE
TYPE / ID


Primary ,Secondary & SSP Library Building Communication Room PS501.22, HS611.04, SSP611.03

Schedule Area 8.4 m2

Notes

- **1** Minimum Room requirements are Critical Dimensions due to equipment being installed.
- **2** Minimum Ceiling height is 2400mm
- **3** All cable pathways into cabinets are to be via cable trays installed above 2100mm
- **4** "If the total number of telecommunications outlets terminated in a communications cabinet exceeds 192, or there is less than 20% expansion capacity, then a second cabinet may be required."

Building Communications Room (BCR) (Single Cabinet)



Building Communications Room (BCR) (Dual Cabinet)

